

PREVENTIV PA ÇMIME

Nr.	Nr. Analizës	Përshkrimi punimeve	Njësia	Sasia	Çmimi	Vlera
PUNIME NDERTIMORE						
1	An-N. 1	Prishje Pllakash ekzistuese	m ²	600,0		
2	An-N. 2	Prishje e shtresave te betonit per kalimin e linjave te ujit	m ²	600,0		
3	2.426/11	Prishje e Suva brenda mur tulle ~ 4m, me krah, llaç	m ²	120,0		
4	2.426/1	Prishje mur tulle me pastrim	m ³	40,0		
5	2.267/a	Shttrim me pllake gres porcelanat importi	m ²	600,0		
6	2.262/3	Shtrese betoni C 12/15 per nivelim , t=10 cm (dysHEME)	m ³	60,0		
7	2,264	Shtrese lluster çimento 1:2	m ²	600,0		
8	2.310	Suva brenda mur tulle h-4m me krah, llaç i perzier M25	m ²	122,0		
9	2.297/a	Veshje tavani me kartonxhes	m ²	13,0		
10	2,328	Patinim muri allçi (stuko)	m ²	122,0		
11	2.404/1	Boje hidroplastike cilesi e larte ose ekujvalente	m ²	122,0		
12	2.86.	Mure me tulle me 6 vrima, t=12cm, h-12cm, llaç perzier M15	m ³	40,0		
13	2.324a	Plintues grez importi, h=10 cm	ml	300,0		
14	2.37/5b	Transport mbeturina me auto deri ne 10 km	m ³	50,0		
		SHUMA 1				
PUNIME PER INSTALIMIN E SISTEMEVE MEKANIKE						
IMPIANTI I NGROHJES						
SISTEMI HIDRONIK						
1	An-N. 3	F.V Tuba çeliku pa tegel + rakorderi, Ø 3/4 "	kg	143,0		
2	An-N. 4	F.V Tuba çeliku pa tegel + rakorderi, Ø 1 "	kg	333,0		
3	An-N. 5	F.V Tuba çeliku pa tegel + rakorderi, Ø 1 1/4 "	kg	165,0		
4	An-N. 6	F.V Tuba çeliku pa tegel + rakorderi, Ø 1 1/2 "	kg	652,0		
5	An-N. 7	F.V Tuba çeliku pa tegel + rakorderi, Ø 2 "	kg	709,0		

6	An-N. 8	F.V Tuba çeliku pa tegel + rakorderi, Ø 3 "	kg	153,0		
7	An-N. 9	F.V Tubo PEX/al,DN 12 (Ø16 X 2.0) mm, i termoizoluar $\delta=6$ mm	ml	1 500,0		
8	An-N. 10	F.V Elektroda saldimi	kg	12,0		
9	2.535/I	Termoizolim tubo, lesh xhami, llaam, material tero, rrjete >	m ²	1,0		
10	2.535/a	Termoizolim tubi, Ø 1/2" me armoflex (d22x9) >	ml	652,0		
11	2.535/d	Termoizolim tubi, Ø 1 1/4" me armoflex (d42x9) >	ml	56,0		
12	2.535/c	Termoizolim tubi, Ø 1" me armoflex (d35x9) >	ml	151,0		
13	2.535/b	Termoizolim tubi, Ø 3/4 "me armoflex (d28x9) >	ml	101,0		
14	2.494/2	F.V Saraçenesk bronxi Ø 1" - 25 mm >	copë	24,0		
15	2.494/1	F.V Saraçenesk bronxi Ø 3/4 " - 20 mm >	copë	40,0		
16	An-N. 11	F.V. Cajrues	copë	64,0		
17	An-N. 12	F.V.Kolektor ngrohje 3/4" me (4x4) dalje 1/2", kompletuar me buketon, kaset,tapa,	copë	2,0		
18	An-N. 13	F.V.Kolektor ngrohje 3/4" me (5x5) dalje 1/2", kompletuar me buketon, kaset,tapa,	copë	18,0		
19	An-N. 14	F.V.Kolektor ngrohje 1" me (5x5) dalje 1/2", kompletuar me buketon, kaset,tapa,	copë	7,0		
20	An-N. 15	F.V.Kolektor ngrohje 1 " me (6x6) dalje 1/2", kompletuar me buketon, kaset,tapa,	copë	5,0		
		SHUMA 2				
INSTALIMET E AMBIENTIT TEKNIK						
1	An-N. 16	F.V Grupi i mbushjes automatike	copë	1,0		
2	An-N. 17	F.V Kolektore dergim/rikthim te ujët te ngrohëte Karakteristikat Teknike : Diametri 5 " (DN 125),Çelik 1 hyrje 3 " 1 dajle 1 1/2" 1 dajle 2 " 1 dajle 3 " -Manometer,	copë	2,0		

		-Termometer -Saracineske shkarkimi 3/4"				
3	An-N. 18	F.V Valvul flutur DN 80, Pn 6 bar	copë	6,0		
4	An-N. 19	F.V Valvul flutur DN 65, Pn 6 bar	copë	7,0		
5	An-N. 20	F.V Valvul flutur DN 50, Pn 6 bar	copë	2,0		
6	An-N. 21	F.V Valvul DN25, Pn 6 bar	copë	5,0		
7	An-N. 22	F.V Valvol moskthimi DN 80, Pn 6 bar	copë	3,0		
8	An-N. 23	F.V Valvol moskthimi DN 65, Pn 6 bar	copë	4,0		
9	An-N. 24	F.V Valvol moskthimi DN 50, Pn 6 bar	copë	1,0		
10	An-N. 25	F.V Filter uji me rrjet DN 80, Pn 6 bar	copë	2,0		
11	An-N. 26	F.V Filter uji me rrjet DN 65, Pn 6 bar	copë	2,0		
12	An-N. 27	F.V Filter uji me rrjet DN 50, Pn 6 bar	copë	1,0		
13	An-N. 28	F.V Xhunto antivibruese DN 80	copë	4,0		
14	An-N. 29	F.V Xhunto antivibruese DN 65	copë	4,0		
15	An-N. 30	F.V Xhunto antivibruese DN 50	copë	2,0		
16	An-N. 31	F.V Valvul sigurie DN 25, Pn 6 bar	copë	1,0		
17	An-N. 32	F.V Valvul mishelatriçe tredegese DN 80	copë	1,0		
18	An-N. 33	F.V Valvul mishelatriçe tredegese DN 65	copë	1,0		
19	An-N. 34	F.V Valvul mishelatriçe tredegese DN 50	copë	1,0		
20	An-N. 35	F.V Termometer (0÷120°)	copë	10,0		
21	An-N. 36	F.V Manometer	copë	10,0		
22	An-N. 37	F.V Ajernxjerres automatik	copë	20,0		
23	An-N. 38	F.V Presostat sigurie	copë	1,0		
24	An-N. 39	F.V Flusostat DN100	copë	1,0		
25	An-N. 40	F.V Sensor temperature	copë	5,0		
		SHUMA 3				

		SHUMA TOTALE PUNIME 1+2+3				
		MAKINERI DHE PAJISJE				
		SISTEMI I NGROHJES				
1	An-N. 41	F. Element radiatori alumini per dhoma, Presioni max.6 bar, interaksi 600 mm, $\Delta T_{ek} = 50\text{ }^{\circ}\text{C}$, Fuqia Termike 141 W/el, Tem max $90\text{ }^{\circ}\text{C}$.	copë	2 720,0		
2	An-N. 42	F. Kiti per radiator, Saracinesk (brasfar), element mberthimi, tapa,etj	copë	165,0		
3	An-N. 45	F. Ndares hidraulik, per ndarjen e qarkut primar nga qarku sekondar: Kapaciteti: $50\text{ m}^3/\text{h}$ P.max bar T.punes $0\div 105^{\circ}\text{C}$ Lidhjet $\varnothing 3''$	Copë	1,0		
4	An-N. 46	F. Zbutes uji (Karakteristikat teknike te percaktohen mbasi te dali rezultati i analizave te ujit)	copë	1,0		
5	An-N. 47	F.Ene zgjerimi me diafragme per qarkun primar te kaldajen. Volumi 100 lit Diametri 500 mm Lartesia 820 mm P.max 6 bar T.punes $-10\div 99^{\circ}\text{C}$ Lidhja $\varnothing 3/4''$	copë	3,0		
		SHUMA TOTALE E MAKINERIVE & PAJISJEVE DHE PUNIME PA TVSH				
		T.V.SH SHUMA TOTALE PUNIMEVE 1+2+3 (20%)				
		SHUMA TOTALE MAKINERI DHE PUNIME ME TVSH				